

# STATE OF TEXAS WELL REPORT for Tracking #144711

Owner: **Johnny Smith** Owner Well #: **1**  
Address: **1290 Stonewall St.** Grid #: **68-13-9**  
**New Braunfels, TX 78130**  
Well Location: **5479 Arroyo Luis** Latitude: **29° 46' 48" N**  
**Bulverde, TX 78163** Longitude: **098° 24' 29" W**  
Well County: **Comal** Elevation: **1074 ft. above sea level**

Type of Work: **New Well** Proposed Use: **Domestic**

Drilling Start Date: **5/13/2008** Drilling End Date: **5/14/2008**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	<b>8.75</b>	<b>0</b>	<b>620</b>

Drilling Method: **Air Rotary**

Borehole Completion: **Open Hole**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks &amp; material)</i>
Annular Seal Data:	<b>0</b>	<b>380</b>	<b>5 cement</b>
	<b>0</b>	<b>10</b>	<b>3 cement</b>

Seal Method: **Gravity**

Sealed By: **Hilton**

Distance to Property Line (ft.): **100+**

Distance to Septic Field or other concentrated contamination (ft.): **No Data**

Distance to Septic Tank (ft.): **No Data**

Method of Verification: **tape**

Surface Completion: **Surface Slab Installed**

Water Level: **315 ft. below land surface on 2008-05-15** Measurement Method: **Unknown**

Packers: **6 mil cones plastic 520'**

Type of Pump: **Submersible** Pump Depth (ft.): **561**

Well Tests: **Estimated** Yield: **10 GPM with 40 ft. drawdown after 1 hours**

Water Quality:	<i>Strata Depth (ft.)</i>	<i>Water Type</i>
	<b>No Data</b>	<b>No Data</b>

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **BoMax Industries, Inc.**  
**630 Solo St.**  
**San Antonio, TX 78260**

Driller Name: **Michael E. Stempelmann** License Number: **50146**

Apprentice Name: **Hilton L. Johnson** Apprentice Number: **00001939**

Comments: **No Data**

Lithology:  
 DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:  
 BLANK PIPE & WELL SCREEN DATA

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
<b>0</b>	<b>1</b>	<b>dirt</b>
<b>1</b>	<b>12</b>	<b>caliche limestone</b>
<b>12</b>	<b>35</b>	<b>grey limestone</b>
<b>35</b>	<b>90</b>	<b>grey clay / limestone mix</b>
<b>90</b>	<b>290</b>	<b>grey limestone</b>
<b>290</b>	<b>375</b>	<b>grey clay / limestone mix</b>
<b>375</b>	<b>490</b>	<b>grey limestone</b>
<b>490</b>	<b>515</b>	<b>grey clay</b>
<b>515</b>	<b>620</b>	<b>grey /brown / sandy limestone</b>

<i>Dia. (in.)</i>	<i>New/Used</i>	<i>Type</i>	<i>Setting From/To (ft.)</i>
<b>4.5 "</b>	<b>new</b>	<b>250 psi PVC</b>	<b>from 0 to 620 sdr17</b>
<b>(160' perf.)</b>			

---

**IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY**

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation  
P.O. Box 12157  
Austin, TX 78711  
(512) 334-5540**