

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

1) OWNER: NESLAGE, BILL ADDRESS: 11000 GARY PLAYER CITY: EL PASO STATE: TX ZIP: 79935-3912

2) ADDRESS OF WELL: 5)
County: GILLESPIE GRID # 56-56-3
Street or RFD: .6 MI. W OF MORRIS-TIVY RD. ON TIVYDALE RD.; 400' S IN FIELD
City, State, Zip code: TX -

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC
If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 20218 DIAMETER OF HOLE 7) DRILLING METHOD: 8) BOREHOLE COMPLETION:
DATE DRILLING: 8.75" 0 200 AIR ROTARY/HAMMER GRAVEL PACKED N
STARTED: 06/21/00 6" 200 220 IF GRAVEL... FROM 50 FT. TO 200 FT.
COMPLETED: 06/21/00 FROM FT. TO FT.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
5"	N	PVC CASING	+2	176	SDR 21
5"	N	PVC, CUSTOM SLOTTED	176	196	SCH 40
5"	N	PVC CASING	196	200	SDR 21

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	1	TOPSOIL
1	4	CLAY-BROWN
4	15	CALICHE
15	145	CLAY-RED LIMESTONE LEDGES
145	192	SAND CLAY
192	212	CLAY-RED LIMESTONE LEDGES
212	220	LIMESTONE-BROWN LIMESTONE-GRAY CAMBRIAN

9) CEMENTING DATA:

Cemented from 0 FT. TO 50 FT. No. of Sacks Used 12
FT. TO FT.
Method used: GROUT
Cemented by: TAYLOR VIRDELL JR.
Distance to septic field lines: ft.
Method of verification of above distance:

10) SURFACE COMPLETION:
PITLESS ADAPTER USED

11) WATER LEVEL:
STATIC LEVEL : 142 FT. DATE: 06/21/00
ARTESIAN FLOW: GPM. DATE:

12) PACKERS:	TYPE	DEPTH
	-----	---
	-----	---
	-----	---

13) TYPE PUMP: SUBMERSIBLE DEPTH TO PUMP: 160
14) WELL TEST: JETTED YIELD: 26 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY: TYPE OF WATER: GOOD DEPTH OF STRATA: 145-192 NO STRATA OF UNDESIRABLE WATER PENETRATED
CHEMICAL ANALYSIS MADE 500 T.D.S.

COMPANY NAME: VIRDELL DRILLING INC. WATER WELL DRILLER'S LICENSE NO. 1900 4071 WPKL FOR TWC USE ONLY
ADDRESS: 111 E. GRAYSON ST. CITY: LLANO STATE: TX ZIP CODE: 78643 WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) Taylor VirdeLL (signed) _____
(LICENSED WATER WELL DRILLER) (REGISTERED DRILLER TRAINEE)

R-01961