

46 46.982 116 32.563

IDAHO DEPARTMENT OF WATER RESOURCES  
WELL DRILLER'S REPORT

RECEIVED

MAY 11 2015

IDWR / NORTH

1. WELL TAG NO. D 0067731

Drilling Permit No. 873520  
Water right or injection well # \_\_\_\_\_

2. OWNER

Name BRIAN D. SALMERI  
Address 1011 BRUSHCREEK  
City DEARY State ID Zip 83823

3. WELL LOCATION:

Twp. 40 North  or South  Rge. 2 East  or West   
Sec. 26 1/4 SE 1/4 NE 1/4  
Gov't Lot \_\_\_\_\_ County LATAH

Lat. N46° 50 065 (Deg. and Decimal minutes)  
Long. W116° 32 563 (Deg. and Decimal minutes)  
Address of Well Site .6 MI ON SWENSON LN ON THE RIGHT  
City DEARY

(Give at least name of road + Distance to Road or Landmark)

Lot \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)

New Well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
BENTONITE	0	40	20	DRY

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
8"	+1	41	250	STEEL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6"	35	115	200	PVC	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 41'

9. PERFORATIONS/SCREENS:

Perforations  Y  N Method SAW  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
85	115	1/8x12	50	6"	PVC	200

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 79 Static water level (ft) 45'  
Water temp. (°F) 55 Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port WELL CAP

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	60	1 HR	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water Quality test or comments:

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
12	0	4	SOIL		
12	4	23	CLAY BROWN		
12	23	41	BASALT MEDIUM		
8	41	56	BASALT MEDIUM		
8	56	65	CLAY TAN		
8	65	66	SAND FINE		
8	66	79	CLAY BROWN		
8	79	84	BASALT SOFT		X
8	84	97	BASALT MEDIUM		
8	97	110	BASALT BROKEN		
8	110	115	BASALT MEDIUM		

OFFICE USE ONLY  
Inspected by PLSS  
CORRECT  
Twp \_\_\_\_\_ Rge \_\_\_\_\_ Sec \_\_\_\_\_  
1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4

Completed Depth (Measurable) 115'

Date: Started 9/18/14 Completed 9/21/14

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

MCPHERSON & WRIGHT

Company Name DRILLING Co. No. 0376

\*Principal Driller Ted Wright Date 11/15/14

\*Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Operator II Mary Wright Date 11/15/14

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.