

JACKSON COUNTY DEPARTMENT OF PUBLIC HEALTH

REFERENCE NUMBER J51903L IMPROVEMENT PERMIT	DATE 08.12.04	PIN 7529-51-1715	Marable, Matt
APPLICANT: MILLS RANDALL L PO BOX 1242 PLANT CITY FL 33564-1242		OWNER: MILLS, RANDALL L } MILLS, PATRICIA C PO BOX 1242 PLANT CITY FL	
TELEPHONE: 828.586-3442 <i>Dodd Braucom</i>		EXPIRED NEEDS TO BE RE-EVALUATED UNDER CURRENT RULES	
SPECIFICATIONS: 3			

LOCATION/DIRECTIONS:
BETTY'S CR. R. GAY RD. L. TIMBUKTU. R. DOVE RD. TOP OF RIDGE

FEE: 180	RECEIPT: 4417	SIGNATURE OF OWNER OR AUTHORIZED AGENT: <i>Faxed to HCP 10-5-04 JPP</i>
-------------	------------------	--

The above signature indicates that I have read, understood and concur with all provisions and information as outlined on the back.

SLOPE P/50% TEXTURE P STRUCTURE P DEPTH 5/48"
 IN. DRAIN P EX. DRAIN P 2 LTAR 5 OVERALL P

REMARKS: *Area indicated ok for 3/4" Solvo Septic System repair using 10" Large diameter pipe hand dug! Do not fill or excavate in proposed area. House location and driveway flagged prior to CA being issued. May require pump and pump tank depending on house elevation. * See Attached Plat for sketch.*

OWNER/INSTALLER RESPONSIBLE FOR COMPLIANCE WITH ALL APPLICABLE STATE RULES

DATE 9-3-04
JCDPH-2500 (10/01)

ENV HEALTH SPEC *John R. Paton RS*