

**Rick's Pump Service, Inc.**

1316 Elm Ave.  
 Canon City, CO 81212  
 719-275-7384

**Invoice**

**Invoice #:** 7658  
**Invoice Date:** 1/20/2021  
**Due Date:** 2/3/2021  
**Project:**  
**P.O. Number:** Tim

**Bill To:**  
 Michell Kendall

Date	Description	Amount
1/19/2021	Job Location: 213 Cedar Rd, Westcliffe  Well Test: 1/19/2021 Driller: Alpine Drilling    Date: 8/08/1997    Permit #191427 Well Depth: 300' Static Level: 76' Pump Installer: Ricks Pump Service    Date: 9/09/2002 Pump Intake: 240' Pump Size: 1/2 hp 5 gpm Production Rate: 4 + gpm Well Storage: 246 gallons Pressure Tank: Well Mate 35, added a bit of air to the tank Cistern: N/A This is not a guarantee of any kind. This is what the well produced on the day of the Well Test. We will also have the water sample tested through the Pueblo County Health Department for the results of Coliform and Ecoli.	550.00

Thank you for your business.

<b>Total</b>	<b>\$550.00</b>
<b>Payments/Credits</b>	<b>\$0.00</b>
<b>Balance Due</b>	<b>\$550.00</b>