



## Drinking Water Bacteriological Analysis Results

Pueblo Department of Public Health and Environment Laboratory  
101 W. 9th Street  
Pueblo, CO 81003  
(719) 583-4318  
pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results. The sample number will serve as the invoice number.

Rick's Pump Service  
PO Box 1563  
Canon City CO 81215

**Sample:** 21-0373

**Collector:** Tim/Kendall 1/19/2021 1:30:00 PM

**Address:** 213 Cedar Rd Well Head **County:** Custer

**Analysis Method:** Colilert **Fee for Sample:** \$21.00

**Received By:** Espeseth 1/20/2021 11:15:00 AM

**Results:** **Total Coliform:** Absent **E.coli Result:** Absent

**Date:** 1/21/2021 2:00:00 PM **Analyst:** Espeseth

**Comments:**

Pueblo Department of Public Health and Environment Laboratory is certified by the Colorado Department of Public Health and Environment under primary agreement with the US Environmental Protection Agency to analyze water for coliform bacteria.

Absent means compliance with federal EPA drinking water standards for coliform bacteria.

Total coliform presence with absence of E. coli indicates contamination from a non-warm blooded source such as soil, tree roots, leaves, etc. This does not indicate contamination from fecal material of warm-blooded animals. Treatment of water supply is recommended. Instructions are included for your information.

Total coliform presence with E. coli presence indicates contamination from fecal material of warm-blooded animals. Treatment of water supply is recommended. Instructions are included for your information.

The above descriptions are explanations for the three possible outcomes for results. If "presence" is not listed after the total coliform or E. coli result then treatment of the water supply is not needed.

**Results Information:** This analysis is for coliform bacteria only; no chemical analysis was performed. For further testing please contact a laboratory certified by the Colorado Department of Public Health and Environment for water chemistries. For a current list of certified drinking water laboratories in the state please go to [www.cdphe.state.co.us](http://www.cdphe.state.co.us). Click on "Divisions and Programs". Then click on "Laboratory Services Division". Near the bottom of the page click on "Water Testing Laboratories". This website also has the complete list of analyses performed by the CDPHE laboratory and their pricing.

For further information regarding this analysis, please contact the laboratory at the number above.

**NOTICE:** Effective 1-1-2020 fees for Colilert presence/absence testing will be \$21.00. Fees for Enumerated coliform and E. coli testing will be \$23.00.