

SS-182A
Rev 6/07

West Virginia Department of Health & Human Resources
Haway Department of Health



Application for a Permit to Install or Modify an Onsite Sewage Disposal System

Property Owner Jeremy Shingleton Phone (H) 309-257-0570 (W)
Address Mt. Road City Oldfields State WV Zip Code 260845
Property Location Corner of Mt. Road + Shockey Road Lot # 2

Has this property ever been previously denied for a permit? Yes No Date _____
Facility is New Existing Lot Size _____ Acres /Sq. Ft. Water Source _____
Type Facility Residence Other _____
Number of Bedrooms _____ Number Individuals Served _____ Design Daily Flow _____ gpd
Deed Recorded in Deed Book _____ Page _____ County Tax Map _____ Parcel No. _____
Subdivision Name _____ Approval No. _____ Section _____ Lot _____

The minimum lot size or area reserved for a sewage disposal system in a subdivision may vary based on the date the subdivision was created. On lots created after July 1, 1970, permits for individual sewage disposal systems shall be withheld until a subdivision approval has been granted which indicates that such systems may be expected to comply with applicable design standards on all proposed building lots contained within the original tract.

To the best of my knowledge, the information provided on this application is true and I understand that I am responsible for informing the sewage system installer of the existing or proposed locations of sewage systems and water sources including wells. I further understand that it is my responsibility to consult the sanitarian for assistance as necessary and to determine the location of any existing or proposed sewage systems or wells if presently unknown to me.

Date: 2-8-2018 Signature of Owner: Jeremy Shingleton

Sewage Disposal System Information Lot 2

Application is for a permit to: Install Modify
Check all that apply: Septic Tank Absorption Field Holding Tank Pit Privy Vault Privy
Alternative System (attach detailed plans) Chemical/Composting Toilet Other

Percolation Test: Test Holes #1 205 mins. #2 220 mins. #3 215 mins. #4 190 mins.
Total Minutes = 830 Divided by 24 = 34.5 Average time for water to fall one inch.

Six-foot hole is free of water or solid rock? Yes No Test conducted on (date) _____

I hereby certify that the percolation test was conducted in accordance with the procedures outlined in the Sewage Treatment and Collection System Design Standards, 64CSR47. Notice: all homeowner installers must pass a certification examination administered by the Local Health Department prior to conducting perc testing.

Date: 2-8-2018 Signature of Certified Installer: _____

For Health Department Use: Coordinates N _____ W _____ Date Rec'd _____
Site Eval _____ By _____ Date Fee Pd _____ Rec'd From _____
Permit Issued Denied Permit # _____ Comments _____


Septic Tank: Capacity (gallons) _____ Material _____ Top Seam or Mid Seam
 Manufacturer _____ Outlet Filter Used? Yes No Manufacturer _____

Drain Field: Materials: Gravel Gravelless Pipe Chambers Other _____ Brand _____
 300 ft²/BR 400 ft²/BR Other _____ No. Bedrooms _____ X _____ ft²/BR = _____ total ft²
 No. Lines _____ Length of Lines (ft) _____ Average Depth _____ Max Depth _____ Pipe ASTM No. _____
 Trench Width (ft) _____
 Effluent distribution (check all that apply): Distribution Box Serial Pump dosed Siphon dosed
 If Absorption Bed: Length (ft) _____ Width _____ If chambers: # Used _____ Brand _____

Separation Distances (ft) Septic tank to: Bldg Foundation _____ Property Line _____ Water Supply _____
 Absorption field to: Bldg Foundation _____ Property Line _____ Water Supply _____

Draw a sketch of the property showing any existing or proposed well locations, the location of all structures, property line locations, and the proposed sewage system as it is to be installed. Show all structures and facilities to be served by on-site sewage on the lot.

Design Sketch:



Certified Installer Jeremy Shingleton Telephone 304-257-0570
 Business Address P.O. Box 911 Middlefield WV 26845
 Certification No. 54-19-008 Exp. Date 04-02-2024
 Contractor's License No. WV039173 Exp. Date 02-05-2024 Issued to Shingleton Contracting

I hereby certify that the installation or modification of all parts of the sewage disposal system, including required material standards, will be done in compliance with the Sewage Treatment and Collection System Design Standards Rule, 64CSR47, and appropriate manufacturer's recommended procedures and practices.

Date: 2-8-2018 Signature of Certified Installer: Jeremy Shingleton