



2133 DOUGLAS ST
 FOREST GROVE, OR 97116
 (503)-357-2222 (503)-657-8000
www.clearwaterpumpservices.com
clearwaterpump@hotmail.com

Date Completed: 6/4/24

Customer Name: MIDGE SELTZER

Job Site Address: 8580 SE HILLVIEW DR AMITY
 OR 97101

<u>Time</u>	<u>Flow Rate in Gallons Per Minute</u>	<u>Pumping Level (ft')</u>	<u>Discharge PSI</u>
9:30	15.5	171	45
9:40	15	174	50
9:50	15	175.5	50
10:00	15	177	55
10:10	15	179	55
10:20	15	180	55
10:30	15	181.5	55

Well Log ID: N/A

Static Water Level: 167'

Well Depth: GOT DOWN TO 277' MAY BE PUMP 4" LINER

Pump Type: 2HP SUB AMPS 10.8 ON YELLOW MAY BE 1.5 HP

Pressure Tank: WX-255

Air Pressure: 40PSI

Pressure Settings: N/A

Water Filtration Equipment: NONE THAT WE KNOW ABOUT

Drop Pipe: 1 1/4"	Mineral Test Raw:
Plumbing Size: 1 1/4"	Hardness: 2
Plumbing Type: PVC/ WIRSBO	Iron: 0-.5
Wire Size:#10 TWISTED	PH: 7-7.5
Pitless: YES	TDS:50
Well Seal: PITLESS CAP	SULFUR: NONE
	Mineral Test Treated:
	Hardness:
	Iron:
	PH:
	TDS:
	Sulfur: