

**OFFICE OF THE STATE ENGINEER  
COLORADO DIVISION OF WATER RESOURCES**

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

1280

**WELL PERMIT NUMBER** 273668 - -  
DIV. 2      WD 13      DES. BASIN      MD

APPLICANT

Lot: 131 Block: Filing: Subdiv: CENTENNIAL RANCH

NEIL E & DIANE D SWAN  
9102 HIGH BANKS DR  
EASTON, MD 21601-6834

APPROVED WELL LOCATION

CUSTER COUNTY  
1/4 SE 1/4 Section 1  
Township 24 S Range 71 W Sixth P.M.

DISTANCES FROM SECTION LINES

Ft. from      Section Line  
Ft. from      Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting:      Northing:

(410) 820-9070

**PERMIT TO CONSTRUCT A WELL**

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35.50 acres described as lot 131, Centennial Ranch division of land, Custer County.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns, and the watering of poultry, domestic animals, and livestock on a farm or ranch.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.3 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include either the 1/4, 1/4, Section, Township, Range, and distances from section lines, or a GPS location pursuant to the Division of Water Resources' guidelines.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Test Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us/pubs/forms.asp>. *CAC 5/21/07*

APPROVED  
CDK

*Neil E. Swan*

State Engineer

*Clay K...*

By

Receipt No. 3616781

DATE ISSUED 05-21-2007

EXPIRATION DATE 05-21-2009