

Ziegler Soil Consulting, Inc.
42 Canyon Creek Circle
Lafayette, Indiana 47909

phone: 765-474-3041
toll free: 1-800-621-4400
fax: 765-474-7741

SEPTIC SYSTEM SOIL/SITE EVALUATION REPORT

Prepared for: Kevin Presnell
FFCIC/TL LLS

Address: 1950 S. Morgantown Rd.
Morgantown, IN 46160

(kpresnell@farmflexcapital.com)

Telephone: 317-752-6880 Fax:

Location: South and east side of Skunk Hollow Rd., Martinsville, IN. (see map)

Legal Description: Part of the S 1/2, SE 1/4

Section: 11 T 12N R 2E
Township: Green
County: Morgan

TYPE OF SYSTEM

Purpose: Proposed Replacement/Repair _____
Residential: Commercial: _____
Single Dwelling:
Number of Bedrooms: ?
Water Source: Well ? Public Supply _____


Thomas R. Ziegler, IRSS #33

11-14-24



Contact

Kevin L. Presnell
(317) 752-6880

[Email Us](#)

kpresnell@farmflexcapital.c

[Visit Our Website](#)


kpresnell@farmflexcapital.com <https://www.maf>



39.4917, -86.276

3D


<https://id.land>



Morgan County, IN

SKUNK HOLLOW RD, MARTINSVILLE, IN 46151

55-10-11-400-011.001-009



Parcel Information

Parcel Number: 55-10-11-400-011.001-009

Alt Parcel Number: 55-10-11-400-011.001-009

Property Address: SKUNK HOLLOW RD
MARTINSVILLE, IN 46151

Neighborhood: 1-ENTIRE GREEN TOWNSHIP NORTHWEST

Property Class: Vacant Land

Owner Name: TUTTLE DEBORAH A WALLACE

Owner Address: 7880 SKUNK HOLLOW RD
MARTINSVILLE, IN 46151

Legal Description: S11 T12 R2E S SE 28.94 A

Taxing District

Township: GREEN TOWNSHIP

Corporation: M.S.D. MARTINSVILLE

Land Description

<u>Land Type</u>	<u>Acreage</u>	<u>Dimensions</u>
4	25.849	
6	3.116	

Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL :Lot 1 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol XeB2 Boring No.: 5


Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Efferves- cence
					GR	SZ	SH			
0-7	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
7-12	Bt1	SICL	10YR 5/4	10YR 6/2	2	F	SBK	FI	0	-
				10YR 5/6						
12-30	Bt2	SICL	10YR 5/6	10YR 6/2	2	M	SBK	FI	0	-
				10YR 5/8						
30-48	2Bt3	CL	10YR 5/6	10YR 6/2	2	CO	SBK	FI	5%	-
				10YR 5/8						
48+	2Cd	L	10YR 5/4	10YR 6/1			M	VFI	10%	ES
				10YR 5/6						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 7"
 DEPTH TO DENSE TILL: 48"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 2%
 SLOPE DIRECTION: Various-S
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-30"; Till=30-48+"
 LANDFORM: Till Plain-Swell
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
SKUNK Hollow Rd.



Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL-Lot 2 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol FcA Boring No.: 6



Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Effervescence
					GR	SZ	SH			
0-5	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
5-10	Bt1	SICL	10YR 4/4		2	F	SBK	FI	0	-
10-21	Bt2	SICL	10YR 4/4	10YR 5/2	2	M	SBK	FI	0	-
				10YR 5/6						
21-35	2Bt3	CL	10YR 4/4	10YR 5/2	2	CO	SBK	FI	5%	-
				10YR 5/6						
35+	2Cd	L	10YR 5/4	10YR 6/1			M	VFI	10%	ES
				10YR 5/6						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 10"
 DEPTH TO DENSE TILL: 35"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 2-6%
 SLOPE DIRECTION: Various
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-21"; Till=21-35+"
 LANDFORM: Till Plain-Bevel-Shoulder slope
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
Skunk Hollow Rd.
Lot 2



Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL-Lot 3 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol FcA Boring No.: 4


Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Effervescence
					GR	SZ	SH			
0-8	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
8-13	Bt1	SICL	10YR 5/6	10YR 6/2	2	F	SBK	FI	0	-
				10YR 5/4						
13-28	Bt2	SICL	10YR 5/6	10YR 6/2	2	M	SBK	FI	0	-
				10YR 5/8						
28-47	Bt3	SICL	10YR 5/8	10YR 6/2	2	CO	SBK	FI	0	-
				10YR 5/6						
47-60+	2Bt4	CL	10YR 5/6	10YR 6/1	2	CO	SBK	FI	1%	-
				10YR 5/8						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 8"
 DEPTH TO DENSE TILL: >60"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 1-2%
 SLOPE DIRECTION: Various
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-47"; Till=47-60+"
 LANDFORM: Till Plain-Swell
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
SKUNK Hollow Rd.



Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL-Lot 4 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol FcA Boring No.: 3


Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Efferves- cence
					GR	SZ	SH			
0-8	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
8-14	Bt1	SICL	10YR 5/6	10YR 6/2	2	F	SBK	FI	0	-
				10YR 5/4						
14-25	Bt2	SICL	10YR 5/6	10YR 6/2	2	M	SBK	FI	0	-
				10YR 5/8						
25-41	Bt3	SICL	10YR 5/8	10YR 6/2	2	CO	SBK	FI	0	-
				10YR 5/6						
41-60+	2Bt4	CL	10YR 5/6	10YR 6/1	2	CO	SBK	FI	1%	-
				10YR 5/8						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 8"
 DEPTH TO DENSE TILL: >60"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 1-2%
 SLOPE DIRECTION: Various
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-41"; Till=41-60+"
 LANDFORM: Till Plain-Swell
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
Skunk Hollow Rd.



Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL-Lot 5 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol FcA Boring No.: 2



Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Effervescence
					GR	SZ	SH			
0-7	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
7-12	Bt1	SIL	10YR 5/4	10YR 6/2	2	F	SBK	FI	0	-
				10YR 5/6						
12-26	Bt2	SICL	10YR 5/6	10YR 6/2	2	M	SBK	FI	0	-
				10YR 5/8						
26-43	Bt3	SICL	10YR 5/8	10YR 6/2	2	CO	SBK	FI	0	-
				10YR 5/6						
43-60+	2Bt4	CL	10YR 5/6	10YR 6/1	2	CO	SBK	FI	1%	-
				10YR 5/8						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 7"
 DEPTH TO DENSE TILL: >60"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 1-2%
 SLOPE DIRECTION: Various
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-43"; Till=43-60+"
 LANDFORM: Till Plain-Swell
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
Skunk Hollow Rd.



Septic System Soils/Site Evaluation Form

County Morgan Project FFCIC/TL-Lot 6 Date 11-14-24
 Soil Survey Map No. 31 Map Symbol FcA Boring No.: 1

Depth (inches)	Horizon	Texture	Color	Wetness Features	Structure			Consistence	Rock Fragments	Efferves-cence
					GR	SZ	SH			
0-8	Ap	SIL	10YR 5/3		2	VF	SBK	FR	0	-
8-15	Bt1	SIL	10YR 5/4	10YR 6/2	2	F	SBK	FR	0	-
				10YR 5/6						
15-29	Bt2	SICL	10YR 5/6	10YR 6/2	2	M	SBK	FI	0	-
				10YR 5/8						
29-44	Bt3	SICL	10YR 5/8	10YR 6/2	2	CO	SBK	FI	0	-
				10YR 5/6						
44-60+	2Bt4	CL	10YR 5/6	10YR 6/1	2	CO	SBK	FI	1%	-
				10YR 5/8						

Site Evaluation

DEPTH TO SEASONAL HIGH WATER TABLE: 8"
 DEPTH TO DENSE TILL: >60"
 DEPTH TO BEDROCK: N/A
 DEPTH TO OTHER LIMITING LAYERS: N/A
 PERCENT SLOPE: 1-2%
 SLOPE DIRECTION: Various
 SLOPE SHAPE: Convex
 PONDING: No
 FLOODING: No
 PARENT MATERIAL: Loess=0-44"; Till=44-60+"
 LANDFORM: Till Plain-Swell
 LAND USE: Cropland
 VEGETATION: Corn residue
 REMARKS:

BORING LOCATION ON LANDFORM

Wallace Property
Skunk Hollow Rd.

