



Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · www.gpwaterlab.com · ORELAP# OR100033

Mail To:

Attn: Michelle Helmer
600 Indian Creek Rd
Selma, OR 97538

Date: March 07, 2025
Address of Source: 600 Indian Creek Rd
Sample ID #: 22500707
Project Name: None Provided

Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Doree Schaafsma
Laboratory Director

Sample Information

Sample ID: 22500707	Collectors Name: Michelle Helmer
Address of Source: 600 Indian Creek Rd	Sample Point: Inside Faucet
Project Name: None Provided	Source: Well
Received Date: 03/06/2025	Treatment System: UV Light

Microbiological (Bacteria) Results

Sample Notes:		Collection Date: 03/06/25 2:30 PM					
Contaminate	Method	RESULTS	Units	Date Analyzed	Analyst	ID	Data Flags
Total Coliform	COLILERT	Absent	100ml	3/6/2025 4:46:22 PM	KMB	AC	A
E. Coli	COLILERT	Absent	100ml	3/6/2025 4:46:22 PM	KMB		

This Sample DOES Conform

For samples which do not conform the presence of total coliform bacteria may indicate surface contamination. Although total coliforms are generally harmless, such water is potentially unsafe. In such cases chlorinate the system and resample in 7 days.

See chlorination instructions on the web at: <http://www.gpwaterlab.com/well-chlorination.asp>.

The results of analyses on water samples can only be as good as the sample submitted to the lab. The laboratory examination determines the presence or absence of contamination in the submitted sample only; therefore, no definite conclusions should be drawn from a single test.

Results of Chemical Analysis

Sample Notes:		Collection Date: 03/06/25 2:30 PM								
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Arsenic	SM 3113 B	0.005	ND	mg/L	0.01	03/07/25 3:32 pm	PVS	AA	A	
Nitrate	EPA 300.0	0.5	ND	mg/L	10	03/06/25 7:42 pm	PVS	AB	A	

DEFINITIONS AND DATA FLAGS

A Analysis is covered under ORELAP scope of Accreditation AA Analysis is covered under ISO scope of Accreditation C Sample did not meet acceptance criteria H Analysis performed outside method hold time ID Subsample identifier for each Sample number M Matrix Spike recovery is out of control limits due to matrix interference The LCS was in acceptance limits showing the analysis is in control and the data is acceptable	E Estimated Value LOQ Reporting Limit N/A Not Applicable ND None Detected S Sample Outsourced
---	---

Results Color Key

White - No EPA Limit

Low Risk
within EPA Limit

Medium Risk

High Risk
Exceeds EPA Limit

Call the Lab to Discuss