

# Well Flow Test



**Test ID:** 6853  
**Street Address:** 858 INDIAN CREEK RD  
SELMA, OR 97538

**Test Date:** Aug 05, 2020  
**Service Tech:** JIM HENDERSON

**Name:** BUYER: NICOLE BEHREND  
**Billing Address:** 858 INDIAN CREEK RD  
SELMA, OR 97538  
**Telephone:** 541.507.7461

**Test Requirements:** PERFORM A 4-HOUR OPEN WELL FLOW TEST

**Remarks:**

**Equipment Used:** EXISTING 1/2HP WELL PUMP SYSTEM      **Source:** WELL  
**Well Depth:** Unknown    **Pumping Level:** 0    **Diameter:** 6    **Seal:** Yes    **Vent:** Yes    **Pop Off Valve:** Yes  
**Water Color:** CLEAR    **Taste:** N/A    **Odor:** NONE

## Flow Data

Time	Flow	Level	Meter
10:45 AM	16 GPM	24 feet	240.00 Gallons
11:00 AM	15.5 GPM	34 feet	472.50 Gallons
11:15 AM	15.5 GPM	36 feet	705.00 Gallons
11:30 AM	15.5 GPM	38 feet	937.50 Gallons
11:45 AM	15.5 GPM	38.5 feet	1170.00 Gallons
12:00 PM	15.5 GPM	39 feet	1402.50 Gallons
12:15 PM	15.5 GPM	39 feet	1635.00 Gallons
12:30 PM	15.5 GPM	39 feet	1867.50 Gallons
12:45 PM	15.5 GPM	39 feet	2100.00 Gallons
01:00 PM	15.5 GPM	39 feet	2332.50 Gallons
01:15 PM	15.5 GPM	39.5 feet	2565.00 Gallons
01:30 PM	15.5 GPM	39.5 feet	2797.50 Gallons
01:45 PM	15.5 GPM	40 feet	3030.00 Gallons
02:00 PM	15.5 GPM	40 feet	3262.50 Gallons
02:15 PM	15.5 GPM	40 feet	3495.00 Gallons
02:30 PM	15.5 GPM	40.5 feet	3727.50 Gallons
02:45 PM	15.5 GPM	40.5 feet	3960.00 Gallons

---

<b>Total Time</b>	<b>Total Gallons</b>
4 Hours	3960.00 Gallons

GPM = Gallons per minute being pumped out of well.

Level = The distance from the top of the well to the water level in the well.

Meter = Total gallons of water pumped from well.